



1981/08/25

University of British Columbia
Department of Physical Plant
Acute Care Unit
2211 Westbrooke Mall.
Vancouver, BC V6T 2B5

Attention: Mr. Wolfgang Felix, P. Eng.

Dear Mr. Felix:

RE: FACULTY OF MEDICINE BLDG.
HEALTH PAVILION NORTH
700 West 10th Avenue
Vancouver, BC

Complaints from the employees in the library at the above location continue to be a regular occurrence.

From conversations with yourself and Mr. J. Nelson concerning this problem, it appeared that corrective measures were under way and that the problems of high room temperatures (up to 32° C) and unsatisfactory air quality would soon be resolved.

However, in a recent conversation with Mr. Richard Zilkie of Johnson Controls, I was informed that the contract this company has will not result in any substantial improvement in these conditions.

Please advise this Branch as to what additional work will be done to provide the necessary improvements in this area.

Ralph L. Robson
Inspector

RLR/pr

c.c. Mr. J. Nelson, V.G.H.
c.c. AUCE Local #1